Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 11:32 am

PWS ID: UTAH01018 Name: MINERSVILLE LAKE COUNTY PARK

Legal Contact MINERSVILLE LAKE CNTY PK Rating: Approved

SCOTT ALBRECHT Rating Date: 09/02/2008

Address: P O BOX 789 Activity Status: Active

BEAVER, UT 84713

Phone Number: 435-438-6490

City Served (Area):

County: BEAVER COUNTY

Gal/Day Gal/Min

System Type: Non-community

Activity Status Cd: Active

Population: 100

Last Inv Update: 02/02/2010

Last Inv Update: 02/02/2010

Avg Daily Prod:

Total Dsgn Cap:

Surveyor: PAUL WRIGHT

Total Emerg Cap:

Oper Period: 4/1 to 9/30

Contacts

Contact			Phone Numbers						
Type	Name	Title	Office	Emergency	Email Address				
AC	ALBRECHT, SCOTT		435-438-6490						

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections	
Combined	Unmetered	0	23	
			23 To	tal Svc Connections

Storage

Total Storage: 10,000 GAL	Number of Units: 1	Adequate Capacity: NO
---------------------------	--------------------	-----------------------

No.	Name	Name Type		Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	MINERSVILLE LAKE TANK	Ground	10,000 GAL	Steel		Α	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	MINERSVILLE LAKE PUMP ST	TATIC A		Р			

Distribution System

Pump Type	Total Dyn Head	Pressure	Cross	Auhority
	ft H2O P.S.I.	Adequate	Connection	Statement
		No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	MINERSVILLE LAKE WELL	Active	WL	6	60 GPM	60 GPM	Yes	GW	Permanent	4/1 to 9/30	

Location

^{*}Reports measured flow for wells, approved design capacity for all other sources.